LGAI Technological Center, S.A. (APPLUS) Campus UAB - Ronda de la Font del Carme s/n 08193 Bellaterra (Barcelona) T +34 93 567 2000 CIF: A-63207492 www.appluslaboratories.com



## CERTIFICATE OF CONSTANCY OF PERFORMANCE

LGAI Technological Center, S.A. (APPLUS)
Notified Body Nr. 0370

No

0370-CPR-5614

In compliance with Regulation (EU) Nr. 305/2011 of the European Parliament and the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

POWER, CONTROL AND COMMUNICATION CABLES CABLES FOR GENERAL A LIC TO \$ 100 CONSTRUCTION WORKS SUBJECT TO REACTION TO FIRE REQUIREMENTS.

FAMILY: DMX CLASSIFICATION: Cca-s1a,d al

Placed on the market under the name

## **PVS NV**

KOLMENSTR 149 3512 STF OORT (BELGIUM)

and produced in the manufacturing and

23/32309437

This certific ttests tall ovisions concerning the ascusment and verification of constancy of performance described in ni. 72 of a standard

## EN 505 2014, EN 50575:2014/A1:2016

und system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacture is assessed to ensure the constancy of performance of the construction product.

This certificate was useful issued on 23<sup>rd</sup> April 2021 and will remain valid as long as neither the harmonised standard, the construction resource, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless succeed your withdrawn by the notified product certification body. It is confirmed and modified on 26<sup>th</sup> January 2024.

The monitoring assessment will be done before 31st December 2024

Bellaterra, 26th January 2024

Applus<sup>®</sup>

Xavier Ruiz Peña

Managing Director, Product Conformity B.U.





The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility

LGAI Technological Center, S.A. (APPLUS) Campus UAB - Ronda de la Font del Carme s/n 08193 Bellaterra (Barcelona) T+34 93 567 20 00 CIF: A-63207492 www.appluslaboratories.com



Technical Annex Ed. 1 23/04/2021

## 0370-CPR-5614

Annex according to EN 50575:2014, EN 50575:2014/A1:2016

**POWER, CONTROL AND COMMUNICATION CABLES.** CABLES FOR GENERAL APPLICATIONS IN CONSTRUCTION WORKS SUBJECT TO REACTION TO FIRE REQUIREMENTS.

CROSS SECTIONAL RANGE Conductor of 2 x 7 x 0.20 mm <sup>2</sup> Solv	DESIGNATION	PROAUDIO HC5340° PROAUDIO HC° + UG
	REACTION TO FIRE CLASS	Cca _a,d1,a1
Conductor of 2 x 7 X 0.20 mm <sup>2</sup> 50V	CROSS SECTIONAL RANGE	RATED VO JACE
	Conductor of 2 x 7 X 0.20 mm <sup>2</sup>	50\
	1610	
	19.	
	'	